

Summary of IPRO 320

- Problem Definition
- Scope
- Team Organization
 - **OUniversity Teams**
 - **OData Team**
 - OManagement Team

Three Universities




- University of Chicago
 - OFounded in 1890
 - OHyde Park
- Loyola University Chicago
 - OFounded in 1870
 - ONorth Chicago Lakeshore
- Illinois Institute of Technology
 - OFounded in 1890
 - **OSouth Side**

University of Chicago


- Harper Memorial Library
 - OBuilt in 1910
 - OEnglish Gothic Style from Stone
- Mott
 - OBuilt in 1958
 - OConcrete, Steel and Glass
- SSA
 - OBuilt in 1964
 - **OMies Steel and Glass**

Harper Memorial Library






Est. R value= $1.136 \text{ ft}^2 \text{ (°F)* (hours/BTU)}$



Est. R value= 1.82 ft² (°F)* (hours/BTU)






Est. R value= 1.35 ft² (°F)* (hours/BTU)

Loyola University Chicago

- Flanner Hall
 - OBuilt in 1975
 - **OPoured Concrete**
- Quinland Life Sciences
 - OBuilt in 2004
 - OBrick and Glass Lab Building
- Mundelein Center
 - OBuilt in 1930
 - O15 story stone Art Deco










Est. R value= 3 ft² (°F)* (hours/BTU)

Quinland Life Sciences








Est. R value= 20 ft² (°F)* (hours/BTU)

Mundelein Center






Est. R value= 2.5 ft² (°F)* (hours/BTU)

Illinois Institute of Technology

- Perlstein Hall
 - OBuilt in 1946
 - OBrick, Steel and Glass (Mies)
- S.R. Crown Hall
 - OBuilt in 1956
 - OSteel and Glass (Mies)
- Main Building
 - OBuilt in 1891
 - ORed Brick/Terra Cotta








Est. R value= $10.23 \text{ ft}^2 \text{ (°F)}^* \text{ (hours/BTU)}$

S.R. Crown Hall






Est. R value= 2.67 ft² (°F)* (hours/BTU)








Est. R value= 24ft² (°F)* (hours/BTU)






Pounds of Steam per Sq. Ft for U of C







Steam per Sq. Ft for IIT








- Problems encountered
 - OLoyola did not meter steam by building
 - OU of C did not give total energy produced/used for fiscal year
 - OElectricity information was not broken down by use (ie: electronics, lighting, heating)




Geothermal Energy

- Union cost =\$1,953,641.67; payback =49.83 years
- Non-Union cost = \$1,146,464.67; payback = 29.24 years









Alternatives- Solar Power

- After a cost of \$1025 per panel, and installation costs, this array comes out to \$342,868.67.
- Coupled with our second geothermal site, our total cost with a non-union drilling company comes to \$1,489,333.34.
- With the maximum yearly return, our payback becomes only 11.48 years.



Alternatives- Earth to Air

- At a cost of \$0.46 per Btuh in the installation and purchase of the field, we find the cost of this field to be only \$1,571,436.76.
- This puts the payback of this system at 12.11 years



Alternatives-Recommendations

- The best choice is the ETA system, followed closely by a non-union built solar/geothermal system.
- Regardless of which system is chosen though, we can rest assured that we are using a sustainable system that emits no pollution whatsoever, and doing a small part in making our species more ecofriendly





Campus Recycling



Recommendations ()

- Insulate pipes
- Use thermal imaging to locate 'hot spots'
- Electronic monitoring
- Thicker glass
- Alternative energy





- Team Structure
 - OIn the future, integrate experience levels
 - OGood organization based on concentration
- Other Team Factors

