IPRO 302 – Analysis of Water Recovery from Power Plants for Recycling

Final Presentation December 5, 2008

Presented by:

Don Dornbusch

Wai Kit Ong

Sithambara Kuhan

Dave Malon

Sargent & Lundy





Sargent & Lundy

Sponsor Contacts: Ajay Jayaprakash Dave Stopek



Problem

- Analyze different methods of removing water from flue gas after coal combustion (750 MW plant)
- Why? Limited water resources in various locations around the country that require water for pollution control







Objectives

- Analyze and Cost different methods for removing water
- Determine:
 - Rate of H₂O consumption from FGD
 - Amount of H₂O produced for each technology
 - Cost of H_20 produced (\$/1000gal H_20)
 - Quality of water recovered



Don Faculty Chmiewlewski Advisors

Myron Gottlieb



Project Planning

- Establishing common goals
 - Quality of Work
 - Ethical Research
- Team Code of Conduct
 - Honest, Reliable, Respectful
- Project Schedule
 - Dates for Achievements
 - Allow for Adjustments



Related Projects

- Various Separation
 Techniques
 - Desiccant Siemens
 - Spray Towers (Used in FGD)
 - Heat Exchanger US
 Department of Energy (DOE)







- Advantages
 - Simple maintenance
 - Low risk of fouling and corrosion
 - Low pressure drop

Design Parameters

Part	Parameter		
Tower	Height		7 meters
	Diameter		2 meters
	Primary Material for Construction		Carbon Steel
Nozzles	Туре		Flat cone
	Droplet diameter 7		750 microns
	Operating flow rate		9000 gpm/nozzle
	Operating pressure		470 psi
Pump	Туре		Condensate pump
	Total flow rate		90000 gpm
	Power requirements		8995 HP
Cost			
Capital Cost			\$218,000
Annual Operating Cost			\$3,273,400



Obstacles

- Wide array of variables
- Lack of literature to compare assumptions
- Use of spray systems for pollution control processes rather than cooling
- Low tolerance to pressure drops





Indirect Contact Team



Compact Shell-and-Tube Heat Exchanger



 $h_i A_i \approx h_o A_o$

h – Heat transfer coefficient
A – Heat transfer area
i – Tube-side
o – Shell-side

- Large surface-to-volume ratio
- Increased contact with flue gas
- •Largest average temperature difference
- •Minimized thermal stress
- •Overall cost, weight, volume savings



Design



Design Parameters

	Shel	I-side	Tube-side				
Fluid	Flue	Gas	Water				
Total Flow [kg/h]	4,01	7,500	20,124,000				
Vapor (in/out) [kg/h]	4,017,500 3,750,000		0	0			
Liquid (in/out) [kg/h]	0	267,500	20,124,000	20,124,000			
Temperature (in/out) [°F]	130	100	85	100			
Heat Duty [kJ/h]	7,235,000						
Area [m ²]	26,832						
Capital Cost [US\$]	836,939 ¹						
Annual Operating	F	an	Pump				
Cost [US\$]	2,64	9,004	415,955				

¹ Corrected 2008 value – CE index 746.4

That's 5 Football Fields!





Design Parameters

	Shel	I-side	Tube-side				
Fluid	Flue	Gas	Water				
Total Flow [kg/h]	4,01	7,500	20,124,000				
Vapor (in/out) [kg/h]	4,017,500 3,750,000		0	0			
Liquid (in/out) [kg/h]	0	267,500	20,124,000	20,124,000			
Temperature (in/out) [°F]	130	100	85	100			
Heat Duty [kJ/h]	7,235,000						
Area [m ²]	26,832						
Capital Cost [US\$]	836,939 ¹						
Annual Operating	F	an	Pump				
Cost [US\$]	2,64	9,004	415,955				

¹ Corrected 2008 value – CE index 746.4



Obstacles

- Heat exchanger information not readily available
- Determining actual overall heat transfer coefficient
- Sizing of heat exchanger
 - Tubes
 - Diameter, thickness, length
 - Fins
 - Thickness, height, number of fins per inch



Results and Recommendations

Typical municipal water prices in Canada and other countries (per cubic metre)





Economics

Cost	Direct Contact (US\$)	Indirect Contact (US\$)					
Capital Cost	218,000	836,939					
Operational Cost	3,273,400	3,064,959					
Annualized Cost	3,299,500	3,165,392					
Cost per 1000 Gallons H_2O Recovered	5.28	5.10					

Quality of Water Recovered

Temperature = 85 °F

Pressure = 1 atm

Component	Mass Flows (kg/h)	Mass Percent (%)					
Water	268,000	99.67					
Oxygen	854.72	0.32					
Carbon Dioxide	28.144	0.01					
Nitrogen	2.8981	0.00					
Sulfur Dioxide	0.1782	0.00					
Chlorine	0.00265	0.00					
Argon	0.000462	0.00					
Tota	268,406	100					



Ethical Issues

- Concerns
 - Environmental impact
 - Economics & Resource management
 - Societal impact
 - Sponsor's needs
- Responsibilities
 - Intra-group
 - Inter-communal

Conclusions

Was enough water produced for FGD? YES

- Was the price competitive? NO Feasible?
- Only under restrictive circumstances
 (ex. scarce resources)



Recommendations

- Analyze other technologies
- Only apply one of our methods when resources are scarce.

IPRO 302 – Analysis of Water Recovery from Power Plants for Recycling

Questions/Comments?



References

- ¹ U.S. Department of Energy. <u>http://www.energy.gov/energysources/coal.htm</u> . *Last Reviewed: 10/19/2007.*
- Principles of Flue Gas Water Recovery Systems. © Siemens AG 2005.
- Recovery of Water from Boiler Flue Gas. US Department of Energy. ©11/2006.
- Seider, Warren D., J. D. Seader, and Daniel R. Lewin. <u>Product and Process Design Principles : Synthesis,</u> <u>Analysis, and Evaluation</u>. 2nd ed. San Francisco: Pfeiffer, 2003.
- Singh, Jasbir. <u>Heat Transfer Fluids and Systems for</u> <u>Process and Energy Applications</u>. Danbury: Marcel Dekker Incorporated, 1985.

CE Index

Economic Indicators

2008 2007

JEMAMJJASOND

DOWNLOAD THE CEPCI TWO WEEKS SOONER AT WWW.CHE.COM/PCI

CHEMICAL ENGINEERING PLANT COST INDEX (CEPCI)

(1057.50 100)					650-	 _	_	_	 _	_	_	_	_
(1957-59 = 100)	Aug.'08 Prelim.	Jul. '08 Final	Aug.'07 Final	Annual Index:									
CE INDEX	619.3	608.8	531.5	2000 = 394.1	600								
Equipment	761.0	746.4	632.9	2001 204 2									
Heat exchangers & tanks	784.2	760.1	602.9	2001 = 394.3									
Process machinery	680.6	669.5	601.5	2002 = 395.6	550						Ш		L
Pipe, valves & fittings		875.5	747.4	2003 - 402.0									L
Process instruments	457.8	459.0	428.6	2000 - 402.0						Π	Ш		I
Pumps & compressors		869.9	836.1	2004 = 444.2	500								
Electrical equipment	468.1	468.2	434.5	2005 = 468.2									I
Structural supports & misc		815.8	669.9	2006 - 400 6	450								I
Construction labor	325.1	322.1	317.4	2000 = 455.0	450								I
Buildings	529.7	521.5	478.6	2007 = 525.4									
Engineering & supervision	352.3	352.9	356.4		400								

Starting with the April 2007 Final numbers, several of the data series for labor and compressors have been converted to accommodate series IDs that were discontinued by the U.S. Bureau of Labor Statistics



Project Sponsor:

Sargent & Lundy

Informational Resources:















Calculations