Design and Evaluation of New Flue Gas Cleanup Processes to Meet New EPA Regulations

> IPRO 496-304a Spring 2003

#### **Team Members**

#### Seniors

- Cliff Amundsen
- Abigail Ash
- Wendy Lau
- Anup Patel
- Tyler Wickesberg
- Ben Williams

#### Others

- Syed Ahsan
- Michael Buchanan
- Rita Buresh
- Dimitre Kolev
- Jotvinge Vaicekauskaite
- Tristan Wilson
- Ali Zenfour



Introduction Project Validity Problem Definition Base Case Scenario Operation Descriptions Economic Analysis Process Selection Conclusions/Suggestions

#### **Objectives**

- Design the most cost efficient cleaning process for flue gas that removes SO<sub>x</sub>, NO<sub>x</sub>, Particulate Matter:
  - that meets current and future EPA standards
  - that is viable in the long run
  - based on existing and new technologies
  - which study its effects on cost of electricity by comparing and analyzing costs of burning IL vs. WY coal

#### Introduction – Pollution Control

- Clean Air Act (1990) The EPA institutes new, more vigorous environmental regulations on power plant emissions
- By 2010
  - 6,400 fewer premature deaths
  - \$40B health benefits reduction
- By 2020
  - 12,000 fewer premature deaths
  - \$93B health benefits reduction

#### Clean Air Act (1990) [Ib/mmBtu] OLD PLANTS

	<u>SOX</u>	NOX	<u>HG</u>	<u>P.M.</u>
<u>1980</u>	1.2	0.7	N/A	0.1
<u>2000</u>	0.6	0.4	N/A	0.05
<u>2020</u>	-70%	-70%	-80%	-70%
		<u>NEW PLANTS</u>		
	<u>SOX</u>	<u>NOX</u>	<u>HG</u>	<u>P.M.</u>
<u>1980</u>	X	X	X	<b>X</b>
2000	0.3	0.1	-80%	0.02
<u>2020</u>	-70%	-70%	-80%	-70%

#### Base Plant

 Mid-sized coal burning power plant (400MWe)

Burning Illinois No. 6 coal

 Particulate matter removal only current unit operation (Electrostatic Precipitator (ESP) or Baghouse)

Unit operations to remove  $SO_x$  and  $NO_x$  later.



#### **Coal Statistics**

Wyoming PRB (wt) Illinois No. 6 (wt%) %) • C: 67.37 • C: 49.88 • H<sub>2</sub>: 4.20 • H<sub>2</sub>: 3.40 • N<sub>2</sub>: 1.16 • N<sub>2</sub>: 1.62 • S: 3.25 • S: 0.48 • O<sub>2</sub>: 6.02 • O<sub>2</sub>: 9.82 • Ash: 10.00 • Ash: 6.40 • Moisture: 8.00 • Moisture: 28.40

#### **Coal Combustion**

#### Reactions

- $C_{(s)} + O_{2(g)} \rightarrow CO_{2(g)}$   $\Delta H_{rxn} = -393.509 \text{ kJ/mol}$
- $S_{(s)} + O_{2(g)} \rightarrow SO_{2(g)}$   $\Delta H_{rxn} = -296.830 \text{ kJ/mol}$
- $0.5H_{2(g)} + O_{2(g)} \rightarrow H_2O_{(g)}$   $\Delta H_{rxn} = -241.818 \text{ kJ/mol}$
- $0.5N_{2(g)} + 0.5O_{2(g)} \rightarrow NO_{(g)} \Delta H_{rxn} = 90.250 \text{ kJ/mol}$
- $0.5N_{2(g)} + O_{2(g)} \rightarrow NO_{2(g)}$   $\Delta H_{rxn} = 33.180 \text{ kJ/mol}$

100% conversion of carbon, sulfur, and hydrogen assumed

## **Coal Combustion Calculations**

						Total Grams		
Coal							9.51E+11	
Compound	Wt%	a	M.W.	moles	mole%		Total Pounds	
	0.00		40		4.77	-   -	Heating Value (	Btu/lb)
H2O(g)	8.00	7.01E+10	1ŏ	4.23E+09	4.11		12277.88	
C(s)	67.37	6.41E+11	12	5.34E+10	60.22		Ib Coal/Ho	ur \
	/ 20		2	2.00 = ±10	22.52	┥╷┝	317823.81	
112(9)	4.20	4.000110	۷	2.000 + 10	22.02		158.91	
N2(g)	1.16	1.10E+10	28	3.94E+08	0.44		\$/ton Coa	
S(s)	3 25	3 09F+10	32	9.66E+08	1 0.9	1   F	29.49	
	0.20		00		0.00		<u>\$/yr</u>	
U2(g)	6.02	5.73E+10	32	1.79E+09	2.02		Gas Flow Rate (	ft <sup>3</sup> /min)
C(s,ash)	10.00	9.51E+10	12	7.93E+09	8.94	1 E	1.03E+06	
Sum:	100.00	9.51E+11	X	8.87E+10	100.00	1	Gas Flow Rate	(cm³/s)
							4.042.00	
Flue Gas							<b>Heating Value</b>	Heating Val
Compound	Wt%	g	<u>M.W.</u>	moles	mole%	Ib/mmBtu	(Btu/mol)	<u>(Btu)</u>
CO2(g)	23.61	2.35E+12	44	5.34E+10	16.08	Х	373.22	1.99E+13
SO2(g)	0.62	6.18E+10	64	9.66E+08	0.29	5.29	281.53	2.72E+11
H2O(g)	4.38	4.36E+11	18	2.42E+10	7.29	X	229.35	5.55E+12
NO(g)	0.01	9.19E+08	30	3.06E+07	0.01	0.08	-85.60	-2.62E+09
NO2(g)	0.07	6.58E+09	46	1.43E+08	0.04	0.56	-31.47	-4.50E+09
N2(g)	71.15	7.08E+12	28	2.53E+11	76.14	X	0.00	0.00E+00

3.32E

5.94

767.04

100.00

2.58E+13

Sum:

100.00

9.96E+

Х

#### **Heat Value Calculations**

400MWe/0.35 = 2.7\*10<sup>10</sup>MJ/yr
 2.7\*10<sup>10</sup>MJ/yr\*(1Btu/.001054MJ) = 2.58\*10<sup>13</sup>Btu/yr

2.58\*10<sup>13</sup>Btu/yr\*1lb coal/12,280Btu = 2.1\*10<sup>9</sup>lb coal/yr

2.1\*10<sup>9</sup>lb coal/yr = 158.9ton coal/hr

#### **Coal Selection Dilemma**

- Due to the higher sulfur content, flue gas from Illinois coal must be desulfurized before being released to the atmosphere.
   Under current regulations, Wyoming PRB coal must only undergo a particulate removal process, thereby making it more
  - economical to use.

New regulations, in addition to the Clean Air Act, would require the same cleaning operations (SO<sub>x</sub>, NO<sub>x</sub>, P.M.) for both forms of coal in an attempt to make Illinois coal more competitive.

# Selective Catalytic Reduction

- Selective Catalytic Reduction
  - $2NH_{3(1)} + 3NO_{(g)} \rightarrow$  $2.5N_{2(g)} + 3H_2O_{(g)}$
  - $4NH_{3(g)} + 3NO_{2(g)} \rightarrow$  $3.5N_{2(g)} + 6H_2O_{(g)}$
- Ammonia injected into flue gas before passing through a honeycomb catalyst vessel at 700°F
  - Reaction is pushed to completion to prevent ammonia slip.



### Wet Scrubbing

 A limestone slurry reacts with sulfur dioxide at 300°F to create calcium sulfate, which is trapped in the slurry stream and removed



Scrubbing the Gas

•  $CaCO_{3(aq)} + SO_{2(g)} +$   $0.5O_{2(g)} \rightarrow CaSO_{4(aq)} +$  $CO_{2(g)}$ 

## **Dry Scrubbing**

A saturated calcium hydroxide solution is passed through atomizers so that the droplets evaporate into the flue gas. The calcium hydroxide reacts with the sulfur dioxide and creates calcium sulfate again.

•  $Ca(OH)_{2(aq)} + SO_{2(g)} + 0.5O_{2(g)} \rightarrow CaSO_{4(aq)} + H_2O_{2(g)}$ 

The solid particles are caught in the P.M. removal system as opposed to in the slurry.



### Vessel Design

V = Reaction
 Vessel = [m<sup>3</sup>]

• Q = Flue Gas Flow  $V = Q \cdot \theta$ Rate = [m<sup>3</sup>/s]

θ = Residence
 Time = [s]

#### **Baghouse Filter**

Gas passed through fabric bag network Particulates collect on fabric surface Periodically, particles knocked off bags into hoppers to maintain efficiency and low pressure drop



### **Baghouse Design**

- A = total Baghouse area [ft<sup>2</sup>]
- Q = flue gas flow rate [ft<sup>3</sup>/min]
- F<sub>M</sub> = filtration
  velocity [ft/min] = 2.2

## Electrostatic Precipitator (ESP)

- Uses electric forces to remove particulates
   Ionized particles are attracted to oppositely charged collection plates.
- Particles are dislodged from plates using the rapper



#### **ESP** Design

Design Equation :  $[\ln(1-\eta)]^{1/k} = -\frac{Aw}{C}$ 

 A = total plate area
 w = precipitation rate parameter
 Q = flow rate
 η = efficiency
 k = efficiency constant

Project values: A=  $1.2*10^{6}$  ft<sup>2</sup> w = 0.33 ft/sec Q =  $1.03*10^{6}$  ft<sup>3</sup>/min  $\eta$  = 0.999k = 0.6

### **Vessel Costing**

- Total volume found from previous equations
- Maximum volume from cost correlation graph used to find theoretical number of vessels, each of which has an individual cost
   Summing the individual costs gives total cost for the total volume
  - Costs then inflated to 2003 values

## Vessel Costing Continued

- Baghouse and ESP costs dependent on total area and found through empirical equations
- In addition, total cost has associated costs based on percentages of the bare module cost
  All values inflated to 2003 values

## **Cost Comparison One**

#### Calculated Values

Illinois No. 6	S.C.R.	<u>W.S.</u>	D.S.	B.F.	E.S.P.
CAPITAL	2.43E+07	5.41E+07	4.41E+07	2.68E+07	1.81E+07
OPERATING	3.41E+06	9.74E+06	9.70E+06	2.47E+06	1.99E+06
ANNUALIZED	6.11E+06	1.57E+07	1.46E+07	5.44E+06	4.00E+06
Cents/kW-h	S.C.R.	<u>W.S.</u>	D.S.	<u>B.F.</u>	E.S.P.
ANNUALIZED	0.232	0.599	0.555	0.207	0.152

#### IECM Values

Illinois No. 6	S.C.R.	<u>W.S.</u>	D.S.	B.F.	E.S.P.
CAPITAL	2.27E+07	6.23E+07	4.86E+07	2.46E+07	1.87E+07
<b>OPERATING</b>	3.18E+06	1.11E+07	1.06E+07	2.27E+06	2.08E+06
ANNUALIZED	5.52E+06	1.85E+07	1.56E+07	4.45E+06	3.86E+06
Cents/kW-h	S.C.R.	<u>W.S.</u>	D.S.	<u>B.F.</u>	E.S.P.
ANNUALIZED	0.210	0.702	0.592	0.169	0.147

System of Choice: SCR, Dry Scrubbing, ESP Average Difference (Calculations vs. IECM): 9%



System of Choice: SCR, Dry Scrubbing, ESP

#### **Final Analysis**

Illinois Current Cost (SO<sub>x</sub>, P.M.): 0.739cents/kW-h Wyoming Current Cost(P.M.): 0.124cents/kW-h Diff.:0.615 Illinois New Cost (NO<sub>x</sub>, SO<sub>x</sub>, P.M.): 0.949cents/kW-h Wyoming New Cost(NO<sub>x</sub>, SO<sub>x</sub>, P.M.): 0.713cents/kW-h Diff.:0.236 IL: \$326.48/ton SO<sub>x</sub> removed