

UNIVERSITY BLDG


AL GHUIR UNIVERSITY [DUBAI, UNITED ARAB EMIRATES]

IPRO 323, GROUP THREE

UNIVERSITY BLDG

- Administrative Heart of the University
- “Orientation” point for entry to the University Campus
- Offices, Conference, Auditorium
- Estimated 120,000 Sq. Ft.

AL GHUIR UNIVERSITY



INTRO

STRATEGY




BUILDING

CALCULATIONS

ARCHITECTURAL STRATEGY

- Cooling and ventilation provided with considerably less energy demands vs. traditional strategies
 - Ground Source Heat Pumps
 - Earth Tubes
 - Photovoltaic Arrays
- Submerge building's program into ground
- Aesthetics both contextually appropriate and unique

UNIVERSITY BUILDING







INTRO

STRATEGY

BUILDING

CALCULATIONS

UNIVERSITY BUILDING




INTRO

STRATEGY

BUILDING

CALCULATIONS

UNIVERSITY BUILDING




INTRO

STRATEGY

BUILDING

CALCULATIONS

UNIVERSITY BUILDING



INTRO

STRATEGY

BUILDING

CALCULATIONS

IPRO - AGU

Location	Dubai, UAE
Building owner	AGU
Program user	Jin Lee
Company	Group 3
Comments	

By	CCJM ENGINEERS
Dataset name	C:\CDS\TRACE700\PROJECTS\DUBAITRC.
Calculation time	09:57 AM on 12/01/2003
TRACE® 700 version	4.0

Location	Dubai, United Arab Emirates
Latitude	25.0 deg
Longitude	-56.0 deg
Time Zone	-4
Elevation	50 ft
Barometric Pressure	29.9 in. Hg

Air Density	0.0759 lb/cu ft
Air Specific Heat	0.2444 Btu/lb-°F
Density-Specific Heat Product	1.1132 Btu/h-cfm-°F
Latent Heat Factor	4,900.3 Btu-min/h-cu ft
Enthalpy Factor	4.5542 lb-min/hr-cu ft

Summer Design Dry Bulb	113 °F
Summer Design Wet Bulb	79 °F
Winter Design Dry Bulb	41 °F
Summer Clearness Number	0.90
Winter Clearness Number	0.90
Summer Ground Reflectance	0.20
Winter Ground Reflectance	0.20

Design Simulation Period	January - December
Cooling Load Methodology	TETD-TA1
Heating Load Methodology	UATD



System Checksums

By CCJM ENGINEERS

System - 001

Bypass VAV with Reheat (30% Min Flow Default)

COOLING COIL PEAK					CLG SPACE PEAK		HEATING COIL PEAK			TEMPERATURES		
Peaked at Time:		Mo/Hr: 9 / 15			Mo/Hr: 9 / 16		Mo/Hr: 13 / 1			SADB		
Outside Air:		OADB/WB/HR: 112 / 80 / 104			OADB: 111		OADB: 41			Clg Htg		
Space Sens. + Lat. Btu/h	Plenum Sensible Btu/h	Plenum Latent Btu/h	Net Total Btu/h	Percent Of Total (%)	Space Sensible Btu/h	Percent Of Total (%)	Space Peak Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)	Plenum	Return	Ret/OA
Envelope Loads												
Skylite Solar	0	0	0	0.00	0	0.00	0	0	0.00	76.9	76.9	82.7
Skylite Cond	0	0	0	0.00	0	0.00	0	0	0.00	Fn MtrTD	0.2	0.0
Roof Cond	0	61,366	61,366	2.10	0	0.00	0	-47,953	5.20	Fn BltTD	0.4	0.0
Glass Solar	288,000	0	288,000	9.85	295,200	20.36	0	0	0.00	Fn Frict	1.3	0.0
Glass Cond	15,840	0	15,840	0.54	16,580	1.14	-13,860	-13,860	-1.50			
Wall Cond	24,554	6,608	31,162	1.07	24,630	1.70	-20,462	-26,133	2.84			
Partition	0	0	0	0.00	0	0.00	0	0	0.00			
Exposed Floor	0	0	0	0.00	0	0.00	0	0	0.00			
Infiltration	483,521	0	483,521	16.54	239,787	16.54	-180,341	-180,341	19.56			
Sub Total ==>	811,915	67,975	879,890	30.10	576,177	39.75	-214,663	-268,268	29.11			
Internal Loads												
Lights	40,956	163,824	204,780	7.01	40,956	2.83	0	0	0.00			
People	245,455	0	245,455	8.40	136,364	9.41	0	0	0.00			
Misc	614,340	0	614,340	21.02	614,340	42.38	0	0	0.00			
Sub Total ==>	900,751	163,824	1,064,575	36.42	791,660	54.61	0	0	0.00			
Ceiling Load	71,525	-71,525	0	0.00	81,720	5.64	-30,702	0	0.00			
Outside Air	0	0	879,129	30.06	0	0.00	0	-327,893	35.57			
Sup. Fan Heat			134,824	4.61		0.00		0	0.00			
Ret. Fan Heat		0	0	0.00		0.00		0	0.00			
Duct Heat PkUp		0	0	0.00		0.00		0	0.00			
OV/UNDR Sizing	0	0	0	0.00	0	0.00	-340,786	-340,786	36.97			
Exhaust Heat		-35,409	-35,409	-1.21		0.00		15,199	-1.65			
Terminal Bypass		0	0	0.00		0.00		0	0.00			
Grand Total ==>	1,784,191	124,864	0	2,923,008	100.00	1,449,557	100.00	-585,151	-921,768	100.00		

AIRFLOWS												
	Cooling	Heating										
Vent	10,909	10,909										
Infil	6,000	6,000										
Supply	65,005	19,501										
Minclm	19,501	19,501										
Return	71,005	71,005										
Exhaust	16,909	16,909										
Rm Exh	0	0										
Auxil	0	0										

COOLING COIL SELECTION					AREAS				HEATING COIL SELECTION						
Total Capacity ton	Sens Cap. MBh	Coil Airfl cfm	Enter DB/WB/HR °F °F gr/lb	Leave DB/WB/HR °F °F gr/lb	Gross Total	Glass				Capacity MBh	Coil Airfl cfm	Ent °F	Lvg °F		
Main Clg	292.7	3,511.8	2,730.9	65,005	82.7	63.4	56.4	53.1	43.4	28.3	Main Htg	-1,045.0	19,501	46.9	95.0
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Preheat	-147.4	10,909	41.0	53.1
Total	292.7	3,511.8									Reheat	-458.9	19,501	55.0	68.0
											Humidif	-465.2	16,909	11.8	51.1
											Opt Vent	0.0	0	0.0	0.0
											Total	-1,657.6			

Project Name: IPRO - AGU
Dataset Name: C:\CDS\TRACE700\PROJECTS\DUBAITRC.TRC

TRACE® 700 v4.0 calculated at 09:57 AM on 12/01/2003
Alternative - 1 System Checksums report Page 1 of 1

System Checksums

By CCJM ENGINEERS

System - 001

Bypass VAV with Reheat (30% Min Flow Default)

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK			TEMPERATURES				
Peaked at Time: Mo/Hr: 9 / 15					Mo/Hr: 8 / 16			Mo/Hr: 13 / 1			Cig Htg				
Outside Air: OADB/WB/HR: 112 / 80 / 104					OADB: 114			OADB: 41			SADB 55.0 95.0				
	Space Sens. + Lat. Btu/h	Plenum Sensible Btu/h	Plenum Latent Btu/h	Net Total Btu/h	Percent Of Total (%)	Space Sensible Btu/h	Percent Of Total (%)	Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)	Plenum 76.9 67.2				
											Return 76.9 67.2				
											Ret/OA 83.7 62.1				
											Fn MtrTD 0.2 0.0				
											Fn BldTD 0.4 0.0				
											Fn Frict 1.3 0.0				
Envelope Loads													AIRFLOWS		
Skylite Solar	0	0	0	0.00	0	0.00	0	0	0.00	Cooling Heating					
Skylite Cond	0	0	0	0.00	0	0.00	0	0	0.00	Vent	10,909	10,909			
Roof Cond	0	61,403	61,403	2.30	0	0.00	0	-47,990	5.74	Infil	6,000	6,000			
Glass Solar	96,000	0	96,000	3.59	88,800	7.16	0	0	0.00	Supply	55,835	16,751			
Glass Cond	5,280	0	5,280	0.20	6,000	0.48	-4,620	-4,620	0.55	MinCFM	16,751	16,751			
Wall Cond	8,185	2,204	10,389	0.39	9,271	0.75	-6,821	-8,713	1.04	Return	61,835	61,835			
Partition	0	0	0	0.00	0	0.00	0	0	0.00	Exhaust	16,909	16,909			
Exposed Floor	0	0	0	0.00	0	0.00	0	0	0.00	Rm Exh	0	0			
Infiltration	480,170	0	480,170	17.97	257,153	20.73	-180,341	-180,341	21.56	Auxil	0	0			
Sub Total ==>	589,634	63,607	653,242	24.45	361,224	29.12	-191,782	-241,664	28.89						
Internal Loads													ENGINEERING CKS		
Lights	40,956	163,824	204,780	7.66	40,956	3.30	0	0	0.00	Cooling Heating					
People	245,455	0	245,455	9.19	136,364	10.99	0	0	0.00	% OA	19.5	65.1			
Misc	614,340	0	614,340	22.99	614,340	49.52	0	0	0.00	cfm/ft²	0.47	0.14			
Sub Total ==>	900,751	163,824	1,064,575	39.85	791,660	63.82	0	0	0.00	cfm/ton	210.87				
Ceiling Load	70,759	-70,759	0	0.00	87,587	7.06	-29,939	-29,939	33.68	ft³/ton	453.20				
Outside Air	0	0	873,036	32.68	0	0.00	0	-327,893	39.20	Btu/hr-ft²	26.48	-12.58			
Sup. Fan Heat	0	0	115,807	4.33	0	0.00	0	0	0.00	No. People	545				
Ret. Fan Heat	0	0	0	0.00	0	0.00	0	0	0.00						
Duct Heat PkUp	0	0	0	0.00	0	0.00	0	0	0.00						
OV/UNDR Sizing	0	0	0	0.00	0	0.00	-281,749	-281,749	33.68						
Exhaust Heat	0	-35,030	-35,030	-1.31	0	0.00	0	14,822	-1.77						
Terminal Bypass	0	0	0	0.00	0	0.00	0	0	0.00						
Grand Total ==>	1,561,144	121,643	0	2,671,629	100.00	1,240,471	100.00	-503,471	-836,485	100.00					

COOLING COIL SELECTION										
	Total Capacity ton	Capacity MBH	Sens Cap. MBH	Coil Airfl cfm	Enter DB/WB/HR °F °F g/ib			Leave DB/WB/HR °F °F g/ib		
Main Clg	264.8	3,177.4	2,405.9	55,835	83.7	64.1	58.6	53.1	43.3	26.0
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Total	264.8	3,177.4								

AREAS			
	Gross Total	Glass ft² (%)	
Floor	120,000		
Part	0		
ExFir	0		
Roof	40,000	0 0	
Wall	9,600	2,400 25	

HEATING COIL SELECTION				
	Capacity MBH	Coil Airfl cfm	Ent °F	Lvg °F
Main Htg	-897.6	16,751	46.9	95.0
Aux Htg	0.0	0	0	0
Preheat	-147.4	10,909	41.0	53.1
Reheat	-394.1	16,751	55.0	68.0
Humidif	-465.2	16,909	11.8	51.1
Opt Vent	0.0	0	0	0
Total	-1,510.2			

ENERGY CALCULATIONS

- Conclusions

INTRO

STRATEGY

BUILDING

CALCULATIONS