

IPRO 335 - Capstone Design

Airport of the Future

Plumbing Design


Janet Martinez - Architectural Engineer

Total drainage fixture units for the building = 236 dfu



- Diameter of the pipe connected to the city main = 5"
- Slope of the piping is 1/8" per foot
- Discharge velocity is from 1.93 - 2.23 ft/sec
- Riser diagrams




Main Building Riser Diagram




KEY:
 WC - Water Closet
 UR - Urinal
 LV - Lavatory
 FD - Floor Drain
 KS - Kitchen Sink
 SS - Service Sink




Cooling Loads
 Dan L. Rehberg - Architectural Engineer




AGI32 Lighting Renderings



AGI32 Lighting Renderings



AutoCAD Lighting-Reflected Ceiling Plans



First Floor
 10 branch lines @ 14'
 290 sprinklers total

Second Floor
 East: 4 branch lines @ 12'
 40 sprinklers total
 West: 3 branch lines @ 14'
 54 sprinklers total





A special thanks to ... our very own Professor Jamshid Mohammadi (Advisor), Professor Ali Emadi (Calculations), Professor Joseph Pinnello (Calculations), Professor Ganesh Raman (Acoustics), Professor Ahmed Megri (Component Design), & Professor Ralph Muehleisen (Acoustics).

Cooling Load:
 3,808,856 Btu/hr
 317 tons

Chiller:
 Carrier Aquasnap 30RB060 x3
www.carrier.com

ASHRAE 90.1:
 exceeds code by 1%



Mihdi Vahedi
 Electrical Engineering

Lighting Design

- After adjusting Load Correction Factor for losses in system
- Total AC connected Wattage (maximum) = 350 kW approx.
- Average Watt Hours per Day = 6000 kW Hrs. / Day approx.
- Approximate cost @ \$.08/kW Hrs. = \$14,400.00 per month approx.

